

	31290(5E)-BID QUERY- MAINTENANCE OF 275 KV AND 132 KV HIGH VOLTAGE SUBSTATIONS CIRCUIT BREAKERS FOR A 36 MONTH PERIOD ON AN AS AND WHEN REQUIRED BASIS	Doc.	31156(5E)- Emailed queries		
		Date	08 MAY 2025		
		Rev.	00		
		Page	1	of	1

QUERY 1- Winding Technologies (pty) Ltd

Tender Enquiry Page Ref.	Document Description and Statement/ Query/ Clarification Required
59 of 74	BOQ Item 7- Crane truck hire : Please assist with the size required Item 8- Size lify/Cherry Picker hire: Please assist with the size required
59 of 74	Please confirm which gas pipes are affected, the long SF6 gas pipes or the short SF6 gas pipes.
73 of 74	Please can you share the rating plates/nameplates of the affected Circuit Breakers.

CLARITY FOR QUERY 1:

- For the BOQ Line item 7 – crane truck: 5 tonne
- For the BOQ Line item 8 – Size lify/Cherry Picker hire : 250-350 kg (suitable to reach up to 10 m)
- The long SF6 gas pipes are affected.
- Please refer to Annexure 10.4 of the specification for the types of 275 kV and 132 kV circuit breakers